

**City of Paducah, Kentucky
Engineering Department**

“Pump Station #11”

**ADDENDUM NO. 2
DATE: May 11, 2026**

This document is an Amendment of Invitation to Bid for “PUMP STATION #11 PUMP REPAIR” and shall be a part of and included in the Contract. When the Addendum conflicts with the original Invitation to Bid, this Addendum shall govern.

Questions Received:

- Is a site visit available?
 - Yes, contact Keith Riley at 270-217-7852 to arrange this.
- Is the contract timeframe (30 days) flexible?
 - The City will work with the contractor based on what is found when the pump is pulled, and the fix is determined.
- Is the contractor responsible for performing corrections to the pump?
 - No, the City has engaged Southside Machine Shop in Paducah to perform the corrective work.
- What size crane will be needed to pull the pump?
 - The pump weighs 23,697 lbs. the contractor is responsible for providing the appropriate crane.
- Where will the laydown area be?
 - Laydown will be available on the gravel area at the top of the drive.
- Where will the motor be stored after removal?
 - The motor will need to be stored outside, shrink-wrapped, and tarped to protect it from the weather.

Confirmation: Bidders shall Acknowledge Receipt of this Addendum by signing the last sheet of this Addendum and returning to this office via e-mail at mtownsend@paducahky.gov

City of Paducah



Melanie Townsend
Engineering Project Manager

CONFIRMATION

BIDDERS shall Acknowledge Receipt of this Addendum #1 by signing below and returning to this office via e-mail mtownsend@paducahky.gov.

BIDDER: _____

BY: _____ DATE: _____

TITLE: _____